

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 0111701

Days Creek School
 P O Box 10
 Days Creek, OR 97429

Project: Drinking Water
 Project #: Lead & Copper

Date Reported: 11/24/20
 Date Received: 11/16/20 16:35
 Sampled By: Matt Giles

Client Contact: Matt Giles
 PWSID#: 4192101

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
0111701-01	Sample Location: #1 / Room 201									
	Lead	1030	8	ppb	0.1	15	11/12/20 06:30	11/20/20	N/A	Sub-1
	Copper		20	ppb	0.5	1300	11/12/20 06:30	11/20/20	N/A	Sub-1
0111701-02	Sample Location: #2 / Room 202									
	Lead	1030	4	ppb	0.1	15	11/12/20 06:35	11/20/20	N/A	Sub-1
	Copper		49	ppb	0.5	1300	11/12/20 06:35	11/20/20	N/A	Sub-1
0111701-03	Sample Location: #3 / Room 203									
	Lead	1030	16	ppb	0.1	15	11/12/20 06:37	11/20/20	N/A	Sub-1
	Copper		9	ppb	0.5	1300	11/12/20 06:37	11/20/20	N/A	Sub-1
0111701-04	Sample Location: #4 / Room 204									
	Lead	1030	2	ppb	0.1	15	11/12/20 06:39	11/20/20	N/A	Sub-1
	Copper		84	ppb	0.5	1300	11/12/20 06:39	11/20/20	N/A	Sub-1
0111701-05	Sample Location: #5 / Room 205									
	Lead	1030	12	ppb	0.1	15	11/12/20 06:42	11/20/20	N/A	Sub-1
	Copper		27	ppb	0.5	1300	11/12/20 06:42	11/20/20	N/A	Sub-1
0111701-06	Sample Location: #6 / Elementary DF									
	Lead	1030	ND	ppb	0.1	15	11/12/20 06:45	11/20/20	N/A	Sub-1
	Copper		35	ppb	0.5	1300	11/12/20 06:45	11/20/20	N/A	Sub-1
0111701-07	Sample Location: #7 / Room 207									
	Lead	1030	2	ppb	0.1	15	11/12/20 06:47	11/20/20	N/A	Sub-1
	Copper		117	ppb	0.5	1300	11/12/20 06:47	11/20/20	N/A	Sub-1
0111701-08	Sample Location: #8 / Gym Drinking Fountain									
	Lead	1030	11	ppb	0.1	15	11/12/20 06:52	11/20/20	N/A	Sub-1
	Copper		368	ppb	0.5	1300	11/12/20 06:52	11/20/20	N/A	Sub-1
0111701-09	Sample Location: #9 / Lobby DF									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 0111701

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	ppb	0.1	15	11/12/20 06:55	11/20/20	N/A	Sub-1
Copper			72	ppb	0.5	1300	11/12/20 06:55	11/20/20	N/A	Sub-1
0111701-10	Sample Location: #10 / AG DF									
Lead		1030	0.7	ppb	0.1	15	11/12/20 07:00	11/20/20	N/A	Sub-1
Copper			144	ppb	0.5	1300	11/12/20 07:00	11/20/20	N/A	Sub-1

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 0111701

Qualifiers and Definitions

Sub-1	Subcontracted to Neilson Research Corporation. ORELAP# 100016.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager